



REPUBLIC OF THE PHILIPPINES
Sandiganbayan
 Quezon City

APPROVED FOR POSTING

MA. TERESA S. PABULAYAN
 Executive Clerk of Court IV

BIDS AND AWARDS COMMITTEE

SUPPLEMENTAL BID BULLETIN NO. BID01-2019-01
 March 26, 2019

**Procurement of the Supply and Installation of
 Brand New Air-conditioning Units for the Sandiganbayan**

This Supplemental Bid Bulletin is issued to revise, amend, and/or clarify certain provisions of the Bidding Documents for the above-mentioned procurement project. Accordingly, this shall form an integral part of said Documents.

PARTICULARS					AMENDMENTS/CLARIFICATIONS				
1. Section VII. Technical Specifications I. General Conditions (page 60)					Section VII. Technical Specifications I. General Conditions				
ITEM	DESCRIPTION		QTY	SPECIFICATION	ITEM	DESCRIPTION		QTY	SPECIFICATION
1	OUTDOOR UNIT				1	OUTDOOR UNIT			
	ACCU 1	:	3	20.0 HP		Inverter ACCU 1	:	3	At least 20.0 HP or its equivalent in tonner
	Power Supply			3-phase, 220-240V, 60Hz		Power Supply			3-phase, 220-240V, 60Hz
2	INDOOR UNIT				2	INDOOR UNIT			
	FCU 1	:	32	Ceiling Cassette 3.0 TR					Ceiling Cassette - at least 3.0 HP or its equivalent in tonner
	Power Supply			1-phase, 220-240V, 60Hz		Inverter FCU 1	:	21	
3	ACCESSORIES	:							

		:		Refnet Joints
		:		Wired Remote Controller
		:		Outdoor Piping Connection Kit
	REFRIGERANT	:		R410A
	REFRIGERANT PIPE MATERIAL	:		Seamless High Grade Copper Pipe, Type L
4	PIPE INSULATION	:		Closed Cell Rubber Insulation with Aluminum Braided Tape
	DRAIN PIPE MATERIAL	:		PVC
	CIRCUIT BREAKER ENCLOSURE	:		NEMA 3R
	SPLIT AIRCONDITIONING UNITS	:		
5	FCUs 1	:	6	Floor Mounted. Inverter 3.0 HP
6	FCUs 2	:	161	Wall Mounted Inverter 3.0 HP
7	FCUs 3	:	10	Wall Mounted Inverter 2.0 HP
	REFRIGERANT	:		R32
	Power Supply	:		1-phase, 220-240V, 60Hz

	Power Supply	:		1-phase, 220-240V, 60Hz
3	ACCESSORIES	:		
		:		Refnet Joints
		:		Wired Remote Controller
		:		Outdoor Piping Connection Kit
	REFRIGERANT	:		Manufacturer's Standard that is environment-friendly
	REFRIGERANT PIPE MATERIAL	:		Seamless High Grade Copper Pipe, Type L
4	PIPE INSULATION	:		Closed Cell Rubber Insulation with Aluminum Braided Tape
	DRAIN PIPE MATERIAL	:		PVC
	CIRCUIT BREAKER ENCLOSURE	:		NEMA 3R
	SPLIT AIRCONDITIONING UNITS	:		
5	FCUs 1	:	6	Floor Mounted. Inverter - at least 3.0 HP or its equivalent in tonner
6	FCUs 2	:	161	Wall Mounted Inverter - at least 3.0 HP or its equivalent in tonner
7	FCUs 3	:	10	Wall Mounted Inverter at least 2.0 HP or its equivalent in tonner


4. 13. Documents Comprising the Bid: Financial Component (page 18)

DOCUMENTS	TAB
xxx	
(c) The prospective bidder's audited financial statements, showing, among others, the prospective bidder's total and current assets and liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years (2017 and 2018) from the date of bid submission.	C-3
xxx	

13. Documents Comprising the Bid: Financial Component

DOCUMENTS	TAB
xxx	
(c) The prospective bidder's audited financial statements, showing, among others, the prospective bidder's total and current assets and liabilities, stamped "received" by the BIR or its duly accredited and authorized institutions, for the preceding calendar year which should not be earlier than two (2) years (2016 and 2017) from the date of bid submission.	C-3
xxx	

For the guidance and information of all concerned.


ATTY. MA. TERESA S. PABULAYAN
 Chairperson, Bids and Awards Committee